

State of California
Department of Food and Agriculture
Division of Measurement Standards

Certificate Number: 5111-00
Page 1 of 2

California Type Evaluation Program
Certificate of Approval
for Water Meters

For:

Water Meter
Multi-Jet
Model: FAM Series
Size: 5/8"
Maximum Flow Rate: 15 gpm
Minimum Flow Rate: 0.25 gpm
Minimum Increment: See Table Below

Submitted by:

Master Meter
100 East 15th Street, Suite 350
Forth Worth, TX 76102
Tel: (800) 765-6518
Fax: (817) 336-3840
Contact: Wes Ohlund

Standard Features and Options

Water meter components: Measurement register with lens cover
Measuring chamber
External threaded pipe connection (5/8") in unleaded brass

Unit of measure: Gallons and Cubic Feet (see Table below)
Magnetic drive
Plastic and unleaded brass
Pulse output (Model FAM only) (not evaluated)


Model	Description	Unit of Measure	Minimum Increment
FAM	Three dial register	Gallon	0.005 gal
	Optional electrical output	Cubic Feet	0.0005 Cubic Feet
FAM DIALOG	Single dial register	Gallon	0.1 gal
		Cubic Feet	0.01 cubic feet

NOTE: Approved for use in "Horizontal" or "Vertical" flow positions. The dial face may be rotated and must be turned to face upward in both flow positions.

These devices are to be installed where they are protected from excessive heat and freezing conditions.

This device was evaluated under the California Type Evaluation Program (CTEP) and was found to comply with the applicable technical requirements of California Code of Regulations for "Weighing and Measuring Devices." Evaluation results and device characteristics necessary for inspection and use in commerce are on the following pages.

Effective Date: December 15, 2000


Mike Cleary, Director