
5/8x3/4-inch Sonata Accuracy Testing

Prepared for

Master Meter

December 2018



UTAH WATER RESEARCH LABORATORY

Utah State University Logan, Utah

Report No. 4109

5/8x3/4-inch Sonata Accuracy Testing

Submitted to:

Master Meter 101 Regency Parkway Mansfield, TX 76063

By:

Michael C. Johnson PhD, PE

Utah Water Research Laboratory 8200 Old Main Hill Logan, UT 84322-8200

December 2018

INTRODUCTION

Utah State University was contracted by Master Meter to perform flow calibrations at the Utah Water Research Laboratory (UWRL) in Logan, Utah on six 5/8x3/4-inch Sonata flow meters. The testing required that the new meters be tested for registry accuracy using cold water (water less than 80 degrees Fahrenheit). Each meter was tested at a variety of flow rates specified by Master Meter with a single reading at each flow rate. The readings from the meters were then compared to the volume of water collected during the test runs in a calibrated weight tank.

TEST SETUP

Each 5/8-inch meter was installed in series using adaptors that provided approximately 7 inches between each meter. Potable water from the City of Logan was used for the testing with temperatures maintained at less than 80 degrees. Upstream from the meters were filters to prevent any debris from getting into the meters. Figure 1 shows a sample of the meters tested.



Figure 1. Flow meter installation.

ACCURACY TESTING

Upon receipt of the flow meters from Master Meter, the meters were installed and tested. Table 1 shows the conditions under which each of the meter sizes were tested. The typical draft size for each meter at each flow rate is shown in Table 2.

Table 1. Flow conditions tested and drafts collected.

Target Flow	
Rate	Draft Collected
(gpm)	(gallons)
25	200
20	100
15	20
10	10
2	10
0.4	10
0.13	10
0.10	10
0.05	10

The meters were tested using a gravimetric bench that was certified using NIST traceable weights. The weight of each draft and the temperature were measured for each run.

Through an oversight in setting up the test, runs of 10 and 15 gpm were supposed to have drafts of 100 gallons. However that did not occur. It is always preferable to have larger drafts which are defined in the AWWA standards for testing meters. The results of this calibration demonstrate the robustness of the Sonata meters to accurately meters large flow rates over relatively short durations. As one can readily observe, the 15 gpm flow rate over 20 minutes resulted in a test duration of 1.36 minutes while the 10 gpm test duration was 1.02 minutes.

RESULTS

Tables 1 and 2 show the results of the testing in terms of actual meter registry. The results demonstate impressive registry performance which is to be interpreted by personnel from Master Meter.

Table 1. Utah Water Research Laboratory Flow Meter Evaluation Master Meter 3/4" Sonata Meters

11/20/18 - 11/21/18 Date: M. Day, E. Naulu Bv:

Witness:

Michael Johnson Certified by:

***************************************				Time (min) =	8.01	Flow (gpm) =	24.47								
	25 gpm tests														
Meter	Meter	Initial	Final	Indicated	Initial	Final	Net	Water	H₂O Unit	Actual					
#	S/N	Reading	Reading	Volume	Weight	Weight	Weight	Temp.	Weight	Volume	Registry				
(#)	(#)	(gal)	(gal)	(gal)	(lbs)	(lbs)	(lbs)	(deg F)	(lb/gal)	(gal)	(%)				
1	17M000368	4213.56	4410.31	196.75	4.00	1638.50	1634.50	49.50	8.3431	195.91	100.43%				
2	17M000375	4154.98	4350.34	195.36	4.00	1638.50	1634.50	49.50	8.3431	195.91	99.72%				
3	17M000388	3236.84	3434.03	197.19	4.00	1638.50	1634.50	49.50	8.3431	195.91	100.65%				
4	17M000390	4181.32	4376.94	195.62	4.00	1638.50	1634.50	49.50	8.3431	195.91	99.85%				
5	17M000392	4198.78	4393.98	195.20	4.00	1638.50	1634.50	49.50	8.3431	195.91	99.64%				
6	17M000553	4354.18	4548.70	194.52	4.00	1638.50	1634.50	49.50	8.3431	195.91	99.29%				

				Time (min) =	5.01	Flow (gpm) =	23.20								
	20 gpm tests														
Meter	Meter	Initial	Final	Indicated	Initial	Final	Net	Water	H₂O Unit	Actual					
#	S/N	Reading	Reading	Volume	Weight	Weight	Weight	Temp.	Weight	Volume	Registry				
(#)	(#)	(gal)	(gal)	(gal)	(lbs)	(lbs)	(lbs)	(deg F)	(lb/gal)	(gal)	(%)				
1	17M000368	4461.54	4578.33	116.79	172.00	1141.00	969.00	49.20	8.3432	116.14	100.56%				
2	17M000375	4401.17	4517.21	116.04	172.00	1141.00	969.00	49.20	8.3432	116.14	99.91%				
3	17M000388	3485.29	3602.25	116.96	172.00	1141.00	969.00	49.20	8.3432	116.14	100.70%				
4	17M000390	4427.81	4543.85	116.04	172.00	1141.00	969.00	49.20	8.3432	116.14	99.91%				
5	17M000392	4444.70	4560.46	115.76	172.00	1141.00	969.00	49.20	8.3432	116.14	99.67%				
6	17M000553	4599.22	4714.54	115.32	172.00	1141.00	969.00	49.20	8.3432	116.14	99.29%				

1.36 Flow (gpm) = Time (min) = 14.46 15 gpm tests Meter Meter Initial Final Indicated Initial Net Water H₂O Unit Actual Final Reading Reading Volume Registry # S/N Volume Weight Weight Weight Temp. Weight (#) (#) (gal) (gal) (gal) (lbs) (lbs) (lbs) (deg F) (lb/gal) (gal) (%) 17M000368 19.78 187.00 164.20 8.3432 19.68 100.50% 2 17M000375 4539.75 4559.39 19.64 22.80 187.00 164.20 49.30 8.3432 19.68 99.79% 17M000388 3624.93 3644.71 19.78 22.80 187.00 164.20 49.30 8.3432 19.68 100.50% 3 4586.04 22.80 8.3432 99.95% 4 17M000390 4566.37 19.67 187.00 164.20 49.30 19.68 17M000392 4582.92 4602.53 19.61 22.80 187.00 164.20 49.30 8.3432 19.68 99.64% 5 8.3432 99.39% 4756.55 6 17M000553 4736.99 19.56 22.80 187.00 164.20 49.30 19.68

Time (min) = 1.02 Flow (gpm) = 9.43 10 gpm tests Meter Meter Initial Final Indicated Initial Net Water H₂O Unit Actual S/N Reading Reading Volume Weight Weight Weight Temp. Weight Volume Registry (#) (lbs) (deg F) (lb/gal) (#) (lbs) (gal) (gal) (gal) (lbs) (gal) (%) 17M000368 100 60% 1 4627 70 4637 34 9 64 30.30 110 25 79 95 49 40 8 3431 9 58 17M000375 4575.83 2 49 40 99 35% 4566 31 9.52 30.30 110 25 79 95 8 3431 9 58 3 17M000388 3651 68 3661 24 9 56 30.30 110.25 79 95 49 40 8 3431 9 58 99 76% 4 17M000390 4593.00 4602.61 9.61 30.30 110.25 79.95 49.40 8.3431 9.58 100.28% 5 17M000392 4609.48 4619.05 9.57 30.30 110.25 79.95 49.40 8.3431 9.58 99.87% 6 17M000553 4763.48 4773.00 9.52 30.30 110.25 79.95 49.40 8.3431 9.58 99.35%

Flow (gpm) = 1.96 Time (min) = 2 gpm tests Meter Meter Final Water H₂O Unit Initial Indicated Initial Net Actual Final S/N Reading Reading Volume Weight Weight Weight Temp. Weight Volume Registry (#) (lbs) (#) (gal) (gal) (gal) (lbs) (lbs) (deg F) (lb/gal) (gal) (%) 17M000368 9.82 4.20 82.05 8.3430 9.83 99.85% 2 17M000375 4580.83 4590.60 9.77 4.20 86.25 82.05 49.80 8.3430 9.83 99.34% 3 17M000388 3666.36 3676.14 9.78 4.20 86.25 82.05 49.80 8.3430 9.83 99.44% 4617.47 8.3430 100.05% 4 17M000390 4607.63 9.84 4.20 86.25 82.05 49.80 9.83 8.3430 5 17M000392 4624 17 4633 91 9 74 99.04% 4.20 86.25 82.05 49.80 9.83 6 17M000553 4778.12 4787.83 9.71 4.20 86.25 82.05 49.80 8.3430 9.83 98.73%

Table 2. Utah Water Research Laboratory Flow Meter Evaluation Master Meter 3/4" Sonata Meters

Date: 11/20/18 - 11/21/18
By: M. Day, E. Naulu
Witness: -

Certified by: Medical Johnson

				I ime (min) =	25.03	Flow (gpm) =	0.40							
0.4 gpm tests														
Meter	Meter	Initial	Final	Indicated	Initial	Final	Net	Water	H2O Unit	Actual				
#	S/N	Reading	Reading	Volume	Weight	Weight	Weight	Temp.	Weight	Volume	Registry			
(#)	(#)	(gal)	(gal)	(gal)	(lbs)	(lbs)	(lbs)	(deg F)	(lb/gal)	(gal)	(%)			
1	17M000368	4663.51	4673.57	10.06	129.50	213.65	84.15	52.45	8.3418	10.09	99.72%			
2	17M000375	4601.76	4611.82	10.06	129.50	213.65	84.15	52.45	8.3418	10.09	99.72%			
3	17M000388	3687.33	3697.32	9.99	129.50	213.65	84.15	52.45	8.3418	10.09	99.03%			
4	17M000390	4628.66	4638.64	9.98	129.50	213.65	84.15	52.45	8.3418	10.09	98.93%			
5	17M000392	4645.08	4655.04	9.96	129.50	213.65	84.15	52.45	8.3418	10.09	98.73%			
6	17M000392	4798.99	4808.95	9.96	129.50	213.65	84.15	52.45	8.3418	10.09	98.73%			

Time (min) = **75.03** Flow (gpm) = **0.15**

	0.13 gpm tests														
Meter	Meter	Initial	Final	Indicated	Initial	Final	Net	Water	H₂O Unit	Actual					
#	S/N	Reading	Reading	Volume	Weight	Weight	Weight	Temp.	Weight	Volume	Registry				
(#)	(#)	(gal)	(gal)	(gal)	(lbs)	(lbs)	(lbs)	(deg F)	(lb/gal)	(gal)	(%)				
1	17M000368	4674.43	4685.38	10.95	31.90	123.75	91.85	55.00	8.3404	11.01	99.43%				
2	17M000375	4612.69	4623.69	11.00	31.90	123.75	91.85	55.00	8.3404	11.01	99.89%				
3	17M000388	3698.18	3709.12	10.94	31.90	123.75	91.85	55.00	8.3404	11.01	99.34%				
4	17M000390	4639.50	4650.41	10.91	31.90	123.75	91.85	55.00	8.3404	11.01	99.07%				
5	17M000392	4655.90	4666.86	10.96	31.90	123.75	91.85	55.00	8.3404	11.01	99.52%				
6	17M000553	4809.80	4820.67	10.87	31.90	123.75	91.85	55.00	8.3404	11.01	98.70%				

Time (min) = 101.77 Flow (gpm) = 0.11

	0.1 gpm tests														
Meter	Meter	Initial	Final	Indicated	Initial	Final	Net	Water	H2O Unit	Actual					
#	S/N	Reading	Reading	Volume	Weight	Weight	Weight	Temp.	Weight	Volume	Registry				
(#)	(#)	(gal)	(gal)	(gal)	(lbs)	(lbs)	(lbs)	(deg F)	(lb/gal)	(gal)	(%)				
1	17M000368	4685.51	4696.92	11.41	124.85	220.60	95.75	53.60	8.3412	11.48	99.40%				
2	17M000375	4623.83	4635.32	11.49	124.85	220.60	95.75	53.60	8.3412	11.48	100.09%				
3	17M000388	3709.25	3720.70	11.45	124.85	220.60	95.75	53.60	8.3412	11.48	99.75%				
4	17M000390	4650.55	4661.95	11.40	124.85	220.60	95.75	53.60	8.3412	11.48	99.31%				
5	17M000392	4666.97	4678.37	11.40	124.85	220.60	95.75	53.60	8.3412	11.48	99.31%				
6	17M000553	4820.80	4832.16	11.36	124.85	220.60	95.75	53.60	8.3412	11.48	98.96%				

Time (min) = 200.00 Flow (gpm) = 0.07

	0.05 gpm tests												
Meter	Meter	Initial	Final	Indicated	Initial	Final	Net	Water	H₂O Unit	Actual			
#	S/N	Reading	Reading	Volume	Weight	Weight	Weight	Temp.	Weight	Volume	Registry		
(#)	(#)	(gal)	(gal)	(gal)	(lbs)	(lbs)	(lbs)	(deg F)	(lb/gal)	(gal)	(%)		
1	17M000368	4697.03	4710.03	13.00	162.30	271.35	109.05	56.80	8.3393	13.08	99.41%		
2	17M000375	4635.42	4648.50	13.08	162.30	271.35	109.05	56.80	8.3393	13.08	100.03%		
3	17M000388	3720.80	3733.85	13.05	162.30	271.35	109.05	56.80	8.3393	13.08	99.80%		
4	17M000390	4662.05	4675.06	13.01	162.30	271.35	109.05	56.80	8.3393	13.08	99.49%		
5	17M000392	4678.48	4691.48	13.00	162.30	271.35	109.05	56.80	8.3393	13.08	99.41%		
6	17M000553	4832.26	4845.18	12.92	162.30	271.35	109.05	56.80	8.3393	13.08	98.80%		